

# **MAC Encore™ Performance CLD and WRM Acoustic Test Report**



©2017 HARMAN Professional Denmark ApS. Information subject to change without notice. HARMAN Professional and all affiliated companies disclaim liability for any injury, damage, direct or indirect loss, consequential or economic loss or any other loss occasioned by the use of, inability to use or reliance on the information contained in this document.

Martin®, HARMAN® and all other trademarks in this document pertaining to services or products by HARMAN Professional or its affiliates and subsidiaries are registered as the property of HARMAN Professional Denmark ApS.

HARMAN Professional Denmark ApS - Olof Palmes Allé 18 - 8200 Aarhus N - Denmark - [www.martin.com](http://www.martin.com)

## Title

MAC Encore Performance Acoustic Test Report

## Test conditions

Test carried out according to ISO 3744:2010(E)

## Device tested

Make: HARMAN Professional Denmark ApS

Model: MAC Encore Performance

Serial no: 14200000306

Software version: 1.0.0

## Results

An image of the test setup can be found on page 4. Test results are listed in Table 1 and Table 2 on pages 5 and 6.

HARMAN Professional Denmark ApS, R&D QA are responsible for the test results given in this report.

## Environment

Temperature: 25.2°C Ta

Humidity: 46.2 %RH

AC mains power: 230 V, 50 Hz

Warm-up time: Minimum 30 minutes at full intensity.

Fixture placement: Fixture was placed at least one meter from walls and ceiling, as described in the Standard ISO 3744:2010(E)

## Remarks

Test results apply only to the tested specimen.

| Rev: (last five) | Made by:     | Description:                             | Approved by:    | Date approved: |
|------------------|--------------|--|-----------------|----------------|
| A                | Dennis Svane | MAC Encore Performance Sound Measurement | Markus Klüsener | 2017-09-21     |
|                  |              |  |                 |                |
|                  |              |  |                 |                |
|                  |              |  |                 |                |
|                  |              |  |                 |                |

## Setup

The product was placed indoors in a hemi-anechoic chamber at the test facility of DELTA in Aarhus, Denmark (see Figure 1). The ceiling and walls were all acoustically absorbent and the floor was reflective. The main dimensions of the room were 12 m x 8 m x 4.5 m (length x width x height).



**Figure 1:** Test setup

The product was allowed a minimum of 30 minutes of warm-up time before measurements were performed.

## Measurement method

Measurements were carried out using a setup with 4 microphones. The microphones were in turn moved to the measurement positions described below.

Measurement setup:

- Hemispherical measurement model
- 10 microphone positions in total
- Measurement surface area: 22.7 m<sup>2</sup>

## Instrumentation

Please refer to Page 7 for a full instrumentation list.

## Results

The MAC Encore Performance was measured in 5 different scenarios:

1. All effects static, Light source ON, 100% output white light - Regulated Fan Mode
2. All effects static, Light source ON, 100% output white light - Constant Fan Mode Full
3. All effects static, Light source ON, 100% output white light - Constant Fan Mode Medium
4. All effects static, Light source ON, 100% output white light - Constant Fan Mode Low
5. All effects static, Light source ON, 100% output white light - Constant Fan Mode Ultra-Low

Sound Pressure Levels are listed in Table 1 below. Results of Sound Power Level measurements are listed in Table 2 on Page 6.

| Sound Pressure Levels |  |                                   |                                  |                                  |  |
|-----------------------|--|-----------------------------------|----------------------------------|----------------------------------|--|
| Distance from fixture | Regulated Fan<br>(Max Output)<br>[ dB(A) ] | Constant Fan<br>Full<br>[ dB(A) ] | Constant Fan<br>Mid<br>[ dB(A) ] | Constant Fan<br>Low<br>[ dB(A) ] | Constant Fan<br>Ultra-Low<br>[ dB(A) ] |
| LpA at 0m             | 46.0                                       | 51.0                              | 47.7                             | 44.6                             | 42.5                                   |
| LpA at 1m             | 38.0                                       | 43.0                              | 39.7                             | 36.6                             | 34.5                                   |
| LpA at 4m             | 26.0                                       | 31.0                              | 27.7                             | 24.6                             | 22.5                                   |
| LpA at 7m             | 21.1                                       | 26.1                              | 22.8                             | 19.7                             | 17.6                                   |

Sound Pressure Levels have been converted from Sound Power Levels using the formula:  $LpA = (LwA - \text{reduction}_{\text{distance}})$

Reductions used: 8dB(A)@1m, 20dB(A)@4m, 24.9dB(A)@7m

**Table 1: Sound Pressure Levels**

The measurement results corrected for background noise are listed in the table below for 1/1-octave band and A-weighted values. Results marked with an (\*) do not meet the 6 dB criterion in clause 4.2.1.1 of ISO 3744:2010(E) for the difference between measured sound power level and background noise.

**1/1 Octave bands and A-weighted sound power levels**

| Measured Sound Power Levels            |  |   |  |  |  |
|--|--|---|--|--|--|
| 1/1 Octave band, Hz                    | Regulated Fan<br>(Max Output)<br>[ Lw, dB re.1pW ] | Constant Fan<br>Full<br>[ Lw, dB re.1pW ] | Constant Fan<br>Mid<br>[ Lw, dB re.1pW ] | Constant Fan<br>Low<br>[ Lw, dB re.1pW ] | Constant Fan<br>Ultra-Low<br>[ Lw, dB re.1pW ] |
| 63 Hz                                  | 10.4*  | 13.1                                      | 13.1                                     | 10.4*                                    | 10.9*  |
| 125 Hz                                 | 21.4*  | 23.4                                      | 22.2*                                    | 21.3*                                    | 21.2*  |
| 250 Hz                                 | 35.7   | 41.4                                      | 38.6                                     | 35.3                                     | 34.3   |
| 500 Hz                                 | 40.9   | 46.4                                      | 43.1                                     | 40.3                                     | 37.9   |
| 1000 Hz                                | 42.3   | 46.5                                      | 43.5                                     | 40.1                                     | 37.3   |
| 2000 Hz                                | 37.3   | 42.9                                      | 38.8                                     | 35.5                                     | 33.8   |
| 4000 Hz                                | 28.8*  | 33.5                                      | 29.7*                                    | 28.0*                                    | 28.0*  |
| 8000 Hz                                | 27.0*  | 28.7                                      | 27.3*                                    | 26.6*                                    | 26.4*  |
| <b>A-weighted<br/>(LwA, dB re.1pW)</b> | <b>46.0</b>  | <b>51.0</b>                               | <b>47.7</b>                              | <b>44.6</b>                              | <b>42.5</b>                                    |

*These results are corrected for background noise with a maximum of 1.3 dB only.*

*Results marked with a (\*) do not meet the 6 dB criterion in clause 4.2.1.1 in ISO 3744:2010(E) for the difference between measured sound pressure level and background noise.*

**Table 2: Measured Sound Power Levels**

## Instrumentation

| No.    | Equipment             | Make                 | Type   |
|--------|-----------------------|----------------------|--------|
| 02L021 | Calibrator            | Brüel & Kjær         | 4231   |
| 14L002 | Data acquisition card | National Instruments | NI9233 |
| 14L004 | Data acquisition card | National Instruments | NI9233 |
| 06L038 | ½" Microphone         | G.R.A.S              | 40AE   |
| 06L060 | ½" Microphone         | G.R.A.S              | 40AE   |
| 06L063 | ½" Microphone         | G.R.A.S              | 40AE   |
| 06L064 | ½" Microphone         | G.R.A.S              | 40AE   |
| 09L032 | Preamplifier          | G.R.A.S              | 26CF   |
| 09L037 | Preamplifier          | G.R.A.S              | 26CF   |
| 09L044 | Preamplifier          | G.R.A.S              | 26CF   |
| 09L045 | Preamplifier          | G.R.A.S              | 26CF   |

**Table 3: Instruments Used**

The programs *noiseLAB Capture Professional version 4.0.4* and *Batch processor version 4.1* were used for recording and analysis. All instruments and programs are calibrated regularly in accordance with DANAK guidelines.

