

# MAC Aura Raven XIP

## Acoustic Test Report



©2017-2025 HARMAN Professional Denmark ApS. Information subject to change without notice. HARMAN Professional and all affiliated companies disclaim liability for any injury, damage, direct or indirect loss, consequential or economic loss or any other loss occasioned by the use of, inability to use or reliance on the information contained in this document.

Martin®, HARMAN® and all other trademarks in this document pertaining to services or products by HARMAN Professional or its affiliates and subsidiaries are registered as the property of HARMAN Professional Denmark ApS.

## Purpose

To determine the sound power levels and sound pressure levels of specimen using engineering methods for an essentially free field over a reflecting plane.

## Reference Standard

ISO 3744:2010 Acoustics- Engineering methods

## Device Information

Brand owner HARMAN Professional Denmark ApS  
Model: MAC Aura Raven XIP  
Serial No 15079820072  
Software Version 1.0.0

## Test Environment

Ambient Temperature 26.8 °C  
Relative Humidity 60% RH  
AC main power 230 V @ 50 Hz  
Background noise level 8.9 dBA  
Warm-up time 30 minutes at full intensity

Rev:	Issued by:	Description:	Approved by:	Date approved:
A	Zhoubo Li	MAC Aura Raven XIP Sound Measurement	Verlinden Wouter	2025-04-27

## Test Setup

Room Dimension

5.9m L \* 4.9m W \* 3.3m H

Fixture Installation

At least one meter away from walls and ceiling

Setup pic.



Figure 1 Setup

## Test Procedure

1. Calculate the environmental correction  $K_2$  based on the room dimensions and sound absorption coefficient  $\alpha$
2. Conduct the measurement using a setup with 1 microphone and setup at hemispherical measurement model
3. Move the microphone to each position for the time-averaged sound pressure levels measurement, the duration of each position shall be 15s
4. The details of each position described below as Figure 2:




Figure 2: Microphone Positions

Note:

1. The dimensions of the reference box: 0.595 m x 0.449 m x 0.275 m,  $d_0 = 0.46$
2.  $r = 1.5\text{m} \geq 2d_0$
3.  $S = 2\pi r^2$ , Measurement surface area: 14.137 m<sup>2</sup>.
4. 10 key microphones were taken measurement, as the range of A-weighted sound pressure levels measured at position 1 to 10 does not exceed 10 dB, additional 11 to 20 can be not considered.

The MAC Aura Raven XIP was measured in 5 different scenarios:

1. 100% output white light (Beam + Aura) – Regulate FAN mode
2. 100% output white light (Beam + Aura) – Constant Full FAN mode
3. 100% output white light (Beam + Aura) – Constant Medium FAN mode
4. 100% output white light (Beam + Aura) – Constant Low FAN mode
5. 100% output white light (Beam + Aura) – Constant Ultra-Low power mode

The data of each mode are summarized in Table 1.

Sound Pressure Level					
Distance from fixture	Regulate [ dB(A)]	Constant Full [ dB(A)]	Constant Medium [ dB(A)]	Constant Low [ dB(A)]	Constant Ultra-Low [ dB(A)]
L <sub>w</sub> A at 0m	43.5	56.5	50.6	43.0	31.6
L <sub>p</sub> A at 1m	<b>35.5</b>	<b>48.5</b>	<b>42.6</b>	<b>35.0</b>	<b>23.6</b>
L <sub>p</sub> A at 4m	23.5	36.5	30.6	23.0	11.6
L <sub>p</sub> A at 7m	18.6	31.6	25.7	18.1	6.7
Remark:					
1. $L_{wA} = L_{pA} + 10 \cdot \log_{10}(S)$					
2. $L_{pA_{r2}} = L_{pA_{r1}} + 20 \log_{10}(r_2/r_1)$ , <i>r</i> means the distance between measurement point and fixture					
Test results only apply to the tested specimen					

**Table 1: Sound Pressure Level**

## Instrumentation

Equipment	Brand	Type
Sound Level meter	NTi Audio	NTi XL2 A2A-14709-E0
Microphone	NTi Audio	MIC MA220 No.7587
Temperature & humidity meter	Deli	/
Semi-anechoic room	Harman	/

**Table 2: Instruments Used**