

Test Verification of Conformity

Verification Number: 2504B1323SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

This document can be used in support of a claim in meeting relevant <The Low Voltage Directive2014/35/EU> legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Applicant Name & Address:	HARMAN PROFESSIONAL, INC. 8500 BALBOA BOULEVARD, NORTHRIDGE, CALIFORNIA, 91325, UNITED STATES OF AMERICA
Product Description:	Stage Luminaire
Ratings & Principal Characteristics:	Input:100-240Vac, 50/60Hz, 530W, Class I, IP20, ta 40°C Max. load of outlet: 10A, 100-240Vac
Models/Type References:	ELP MANET ^{8f}
Brand Names:	Martin
Specification<s>/Standards:	EN IEC 60598-2-17:2018 EN IEC 60598-1:2021 + A11:2022 EN 62493:2015/A1:2022
Verification Issuing Office Name & Address:	Intertek Testing Services (Shanghai FTZ) Co., Ltd. Building No. 85 & 86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2025-04-15 to 2025-05-07
Test Report Number(s):	2504B1323SHA-001



Signature

Name: Wenjia Gu

Position: Manager

Date: 21 Aug, 2025

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.